



Certification of Registration

PSG ELECTRICALS PVT LTD

REGISTERED OFFICE : 1483, JANTA FLATS, G.T.B ENCLAVE, DILSHAD GARDEN, DELHI-110093, INDIA

WORK ADDRESS: 18/24/A-1, SITE-IV, INDUSTRIAL AREA, SAHIBABAD, GHAZIABAD, UTTAR PRADESH-201010, INDIA

Certify that the quality management system of the above organisation has been audited and found to be in accordance with the requirements of standard detailed below.

ISO 9001:2015

For The Following Scope

DESIGN, MANUFACTURING AND SUPPLY OF ELECTRICAL DRAW OUT & FIXED TYPE PANELS, PANELS ENCLOSURES AND BUS DUCTS RISING MAINS

Certificate No:- QACS-A-PE-02.21.006

EA Code: 19

**This certificate is issued in accordance with the QA Certification Services Pvt. Ltd. auditing and Certification procedures and certificate shall remain valid subject to yearly surveillance audit.*

Certificate Issue Date: 6th April 2021
Date of Initial Registration: 6th April 2021
Certificate Validity: 3 Years

1st Surveillance Date: 5th April 2022
2nd Surveillance Date: 5th April 2023
***Expiry Date: 5th April 2024**

Note: Certificate shall be valid after surveillance, only if continuation letter by QACS is present.

To Check the certificate validity please
Refer Web:- (www.qacertification.asia)

This certificate is the property of QA Certification Services Pvt. Ltd. and shall be returned immediately when demanded.



Authorised Signatory

QA Certification Services Pvt. Ltd.

G-7, Ground Floor, Vinayak Apartments, Burari-Delhi-110084, INDIA

Email: info@qacertification.asia, www.qacertification.asia

**CENTRAL POWER RESEARCH INSTITUTE
(MEMBER OF STL)**



TEST REPORT

Test Report Number	S2160116	Date :	
Name & address of the Customer	M/s PSG Electricals Pvt. Ltd., 18/24/A-1, Site-IV, Industrial Area, Sahibabad, Ghaziabad-201 010 (U.P)	18 FEB 2016	
Name & address of the Manufacturer	M/s PSG Electricals Pvt. Ltd., 18/24/A-1, Site-IV, Industrial Area, Sahibabad, Ghaziabad-201 010 (U.P)		
Particulars of sample tested	415 V, 4000A, LT Panel (Non Extendable)		
Condition of sample on Receipt	New		
Type	Power Control Centre		
Designation	ACB Panel		
Serial number	Nil		
Number of samples tested	One		
Date(s) of Test(s)	27 th January 2016		
CPRI sample code no.	STDSST216S0143		
Particulars of tests conducted	Verification of the short circuit withstand strength		
Test in accordance with	As per clause 8.2.3 of IS: 8623 (Part -1) 1993		
Sampling plan	Not applicable		
Customer's requirement	Nil		
Deviations if any	Nil.		
Name of the Witnessing persons			
Customer's representative	Shri Pankaj Sharma		
Other than Customer's representatives	Nil		
Test subcontracted with address of the laboratory	None		
Documents constituting this report (in words)			
Number of sheets	Five		
Number of oscillograms	Two		
Number of graphs	Nil		
Number of photos	One		
Number of Test circuit diagrams	Two		
Number of drawings	Four		


(SAUMITRA PATHAK)
TEST ENGINEER




(ANUPAM AWASTHI)
JOINT DIRECTOR

**CENTRAL POWER RESEARCH INSTITUTE
(MEMBER OF STL)**



CPRI

TEST REPORT

Test Report Number S2160116

Date :

18 FEB 2016

Summary of test

Test conducted Verification of the short circuit withstand strength
Rating for which tested 70 kArms for 1.0 second with initial peak of 154 kA

Documents constituting this report

Oscillogram number S2160116. S02, S04
Photograph numbers P-1
Test circuit diagram number OLTS/TCD-STC-01 & OLTS/TCD-STC-02
Drawing number PSG-01-101 Sheet 1 of 4
PSG-01-101 Rev.R1 Sheet 2 of 4
PSG-01-101 Rev.R1 Sheet 3 of 4
PSG-01-101 Rev.R1 Sheet 4 of 4



TEST ENGINEER

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

CPRI

Test Report Number & Date	CPRIRTLHV2015T115	Date: 16.09.2015
Name and address of the Customer	M/s PSG Electricals Pvt. Ltd. 18/24/A-1, Site-IV, Industrial Area, Sahibabad, Ghaziabad-201010 (U.P.)	
Name & Address of the Manufacturer	M/s PSG Electricals Pvt. Ltd. 18/24/A-1, Site-IV, Industrial Area, Sahibabad, Ghaziabad-201010 (U.P.)	
Particulars of the apparatus Tested	415 Volts, 1000 Amp. 3-Phase, Electrical Control Panel	
Condition of sample on receipt	New	
Type	Control Panel	
Designation	LT Panel	
Serial Number	Nil	
No. of samples tested	One	
Date(s) of test(s)	15.09.2015	
CPRI Code No.	CPRIRTLHV2015S105	
Particulars of test conducted	1. Verification of Temperature Rise Limits 2. Dry Power Frequency Voltage Withstand Test	
Test in accordance with standard/Specification	IS: 8623 (Part-1), 1993, RA2004.	
Sampling Plan	Not Applicable	
Customer's requirement	Temperature Rise Limits	
Deviation if any	Nil	
Name of the witnessing person		
a) Customer's representative	Mr.Pavan Sharma (Q.C.Engineer)	
b) Other than Customer's representative		
Test Subcontracted with address of lab.	None	
Document constituting this report(in words)		
Number of sheets	Four	
Number of Oscillograms	Nil	
Number of graphs	Nil	
Number of photos	Nil	
Number of Circuit Diagrams	Nil	
Number of Drawings	Four (Drawing No. PSG-01-101, Sheet 1 of 4, PSG-01-101, Sheet 2 of 4, PSG-01-101, Sheet 3 of 4 & PSG-01-101, Sheet 4 of 4)	
(L.N.Giri) Test Engineer		(S.Bhattacharyya) Unit-Head

केन्द्रीय विद्युत अनुसंधान संस्थान
Sheet 1 of 4

CENTRAL POWER RESEARCH INSTITUTE
(Member of STL)



CPRI

TEST REPORT

Test Report Number : CPRIBPLSTNC19T0066 Dated : 08.05.2019

Name & Address of the Customer : M/s PSG Electricals Pvt. Ltd.
18/24/A-1, Site IV, Industrial Area,
Sahibabad-201010, Ghaziabad(U.P.)

Name and Address of the Manufacturer : M/s PSG Electricals Pvt. Ltd.
18/24/A-1, Site IV, Industrial Area,
Sahibabad-201010, Ghaziabad(U.P.)


Particulars of sample tested : 415V,600A, LT Panel

Condition of sample on receipt : New
Type : LT Panel
Designation : NIL
Description of test sample : 415V,600A, LT Panel
Serial Number : NIL
Number of samples tested : One
Date(s) of Test(s) : 23/01/2019
CPRI sample code number(s) : STNC19S0041
Detail(s) of sealing(s) of sample(s) : No
Particulars of tests conducted : Degree of Protection IP-55 (Category – 1)

Test in accordance with Standard/specification : As per Cl. 8.2.7 of IS:8623 (Part-1), 1993/IEC(Pub) 439-1, 1985
Sampling Plan : NIL
Customer's Requirement : NIL
Deviations, if any : NIL

Name of the witnessing persons :
Customer's representatives : Mr. Dhanraj Chauhan
Other than customer's representatives : NIL
Test subcontracted with name and address of the laboratory : NONE

Documents constituting this report (in words)
Number of sheets : FIVE
Number of oscillograms : NIL
Number of graphs : NIL
Number of photos : NIL
Number of Test circuit Diagrams : NIL
Number of Drawings : ONE


(A.K.Khanra)
Test Engineer




(Sumbul Munshi)
Joint Director
Approved by

ULR - TC5181190STCT0066F

SWITCHGEAR TESTING & DEVELOPMENT STATION
GOVINDPURA, BHOPAL 462023, INDIA
Phone : +91(0)755 2586682 Fax : +91(0)755 2587774

Sheet 1 of 5

CENTRAL POWER RESEARCH INSTITUTE
(Member of STL)



TEST REPORT

Test Report No. : CPRIBPLSTNC1819T0296 Dated : 15 MAY 2019

Name and Address of the Customer : M/s. PSG Electricals Pvt. Ltd.,
18/24/A-1, Site-IV, Industrial area,
Sahibabad, Ghaziabad - 201 010 (U.P.)

Name and Address of the Manufacturer : M/s. PSG Electricals Pvt. Ltd.,
18/24/A-1, Site-IV, Industrial area,
Sahibabad, Ghaziabad - 201 010 (U.P.)

Particulars of Sample(s) Tested : 415V, 250A, LT Panel

Condition of sample(s) on receipt : New
Type : L T Panel Box
Description of test sample : NIL
Serial Number(s) : NIL
Number of Sample(s) Tested : One
Date(s) of Test(s) : 31/07/2018 & 01/08/2018
CPRI sample code number(s) : STNC1819S0200
Sealing of the sample, if any : ONE

Particulars of test(s) conducted : Degree of protection IP -55 (Category -2).

Test(s) in accordance with Standard/specification : As per Cl. 8.2.7 of IS : 8623 (Part-1), 1993 / IEC pub 439-1 (1985)
Sampling Plan : NIL
Customer's Requirement : NIL
Deviations, if any : NIL


Name of the witnessing persons

Customer's Representatives : Mr. Dhanraj Chauhan
Other than Customer's Representatives : NIL


Test subcontracted with name and address of the laboratory : NONE

Documents constituting this report (in words)

No. of Sheet(s) : FIVE
No. of Oscillogram(s) : NIL
No. of Graph(s) : NIL
No. of Photograph(s) : NIL
No. of Test Circuit Diagram(s) : NIL
No. of drawing(s) : ONE


(A.K. KHANRA)
TEST ENGINEER




(SUMBUL MUNSHI)
JOINT DIRECTOR
APPROVED BY



भारत सरकार
राष्ट्रीय परीक्षण शाला (उ०क्षे०)
कमला नेहरु नगर, गाजियाबाद-201 002

Government of India
National Test House (NR)
KAMLA NEHRU NAGAR, GHAZIABAD-201 002

परीक्षण प्रमाण पत्र
TEST CERTIFICATE

INTERIM/FINAL REPORT

1150560

परीक्षण प्रमाण पत्र सं
Test Certificate No
NTH(NR)/EL(HV)/2015/0053

जारी होने की तिथि
Date of Issue
22/09/2015

कोड नं
Code No
1442389047867

पृष्ठ
Page
1

पृष्ठों की संख्या
No of Pages
2

जिसे जारी करना है
Issued To

: PSG ELECTRICALS PRIVATE LIMITED

पता
Address

: 18/24/A-1, Site - IV, Industrial Area, Sahibabad, Ghaziabad -
201010

ग्राहक का सन्दर्भ सं एवं दिनांक
Customer's Ref. No.

: NIL

Date: 14/09/2015

पंजिका सं एवं दिनांक
Register No & Date

: 0053/NTH(NR)/EL(HV)/21/09/2015

: Electrical Panel

परीक्षण सामग्री का विवरण
Description of Test Item

परीक्षण सामग्री का पहचान
Identification of Test Item

: Make : PSG Electricals

नमूना का विशिष्टि (यदि हों)
Product Specification (If any)

: N.A.

नमूना प्राप्ति की तिथि
Date of Receipt of the Test Item

: 16/09/2015

कार्य सम्पादन की तिथि
Date(s) of Performance of Tests

: From: 21/09/2015

To: 22/09/2015

व्यावहृत प्रणाली का पहचान
Method(s) used for Test

: As per IS 60529 - 2001.

नमूना प्रक्रिया वही प्रासंगिक हों
Sampling Procedure where relevant

: Not Applicable

Tested By

Ritu Raj Srivastava
SO Electrical

Checked By

S.K. Mathur
Scientist-SC(Electrical)

Approved By

Kedar Nath Mishra
Scientist-SD(Electrical)



भारत सरकार
राष्ट्रीय परीक्षण शाला (उ०क्षे०)
कमला नेहरु नगर, गाजियाबाद-201 002

Government of India
National Test House (NR)
KAMLA NEHRU NAGAR, GHAZIABAD-201 002



परीक्षण प्रमाण पत्र

TEST CERTIFICATE

INTERIM/FINAL REPORT

1150560

परीक्षण प्रमाण पत्र सं
Test Certificate No
NTH(NR)/EL(HV)/2015/0053

जारी होने की तिथि
Date of Issue
22/09/2015

कोड नं
Code No
1442389047867

पृष्ठ
Page
2

पृष्ठों की संख्या
No of Pages
2

Sl. No.	Test Name	Test Result	Limit
1	Test for 1st Characterestic Numeral '5'	As per Annexure	As per Annexure
2	Test for 2nd Characterestic Numeral '5'	As per Annexure	As per Annexure
टिप्पणी Note	Duly verified Drawing Sheet No. PSG-02-101 for Dimensions only is enclosed here-with and form a part of this test certificate.		
कैफियत Remarks	The sample so far as it has been examined and tested meets to the requirements of IS 60529 - 2001 for "IP-55" class of Protection.		

Tested By

Ritu Raj Srivastava
SO Electrical

Checked By

S.K. Mathur
Scientist-SC(Electrical)

Approved By

Kedar Nath Mishra
Scientist-SD(Electrical)



भारत सरकार
राष्ट्रीय परीक्षण शाला (उ०क्षे०) National Test House (NR)
कमला नेहरु नगर, गाजियाबाद-201 002 KAMLA NEHRU NAGAR, GHAZIABAD-201 002

TC No.: NTH(NR) / EL(HV) / 2015 / 0053

Code No.:1442389047867

Page 1 of 1

ANNEXURE

Sample :- Electrical Panel

Test :- "IP-55" Class of Protection

Specification No. : IS : 60529 - 2001

MARKING :

PSG
PSG ELECTRICALSPVT. LTD.
Mfrs Of:


PCC/MCC/PDB/AC DRIVE PANEL/PLC PANEL/DG PANEL/CAPACITOR PANEL/BUS
DUCT/RISING MAIN/METER BOARD

18/24/A-1, Site – IV, Indl. Area SAHIBABAD – 201010 GZB (UP)
Ph – 0120-4317261 E-mail : psgelectricals2014@gmail.com


TESTS:

TEST	REQUIREMENTS OF SPECIFICATION	OBSERVATIONS
Test for 1 st Characteristic Numeral '5' i.e. Dust Protected. (Clause 13.4)	Dust shall not penetrate in a quantity to interfere with the satisfactory operation of the apparatus or to impair safety.	Satisfactory
Test for 2 nd Characteristic Numeral '5' i.e. protected against water jets. (Clause 14.2.6)	Water projected in powerful jets against the enclosure in any direction shall have no harmful effect.	Satisfactory


Tested By


(R. R. SRIVASTAVA)
Scientific Officer (Electrical)

Checked By


(S.K. MATHUR)
Scientist SC (Electrical)

Approved By


(K. N. MISHRA)
Scientist SD (Electrical)



GOVERNMENT OF UTTAR PRADESH
OFFICE OF THE Deputy Commissioner Of Industries
DISTRICT INDUSTRIES CENTER ,GHAZIABAD
Acknowledgement PART-II

1. M/s **PSG ELECTRICALS PVT. LTD. (DIRECTOR - PANKAJ SHARMA)**, HAS FILLED MEMORANDUM FOR A **MANUFACTURING** ENTERPRISE SETUP AT THE ADDRESS **18/24/A-1 SITE-4 INDL. AREA SAHIBABAD GHAZIABAD U.P.** FOR THE ITEM / ITEMS INDICATED BELOW AS PER THE FACTS STATED IN FORM NO **11556** AND ALLOCATED ENTREPRENEURS MEMORANDUM NO. AS BELOW:

DETAILS OF ITEM / ITEMS TO BE MANUFACTURED / SERVICE TO BE PROVIDED.

Sr No.	Items Of Manufacture / Types Of Service To Be Rendered	Capacity In Case Of Manufacture	Unit	Initial Date Of Production / Commencement Of Service
1.	Control panel	1500.00000	NO	27/01/2015

Sr No.	Investment In Plant And Machinery	Unit
1.	15.00000	Rs in Lakh

4. NOTE : THE ISSUE OF THIS ACKNOWLEDGEMENT DOES NOT BESTOF ANY LEGAL RIGHT. THE ENTERPRISE IS REQUIRED TO SEEK REQUISITE CLEARANCE / LICENSE / PERMIT REQUIRED UNDER STATUTORY OBLIGATION STIPULATED UNDER THE LAWS OF CENTRAL, GOVERNMENT / STATE GOVERNMENT / UT ADMINISTRATION /COURT ORDERS.

5. **DATE OF CHANGE OF CATEGORY FROM MICRO / SMALL TO SMALL / MEDIUM OR VICE VERSA** 30/01/2015 (DD/MM/YYYY)

6. **DATE OF ISSUE** 30/01/2015 (DD/MM/YYYY)

7. **NATURE OF ACTIVITY**(MANUFACTURING -1, SERVICES-2) 1

8. **CATEGORY OF ENTERPRISES** (MICRO-1, SMALL-2, MEDIUM-3) 1

9. **ENTREPRENEURS MEMORANDUM NUMBER**

0 9 0 0 9 1 1 1 1 5 5 6

PART-II /

2015

(FIRST TWO BOXES ARE FOR STATE/UT CODE, NEXT THREE BOXES ARE FOR DISTRICT CODE, SIXTH AND SEVENTH BOXES ARE FOR CATEGORY OF ENTERPRISE (SIX BOX FOR INDICATING MANUFACTURING OR SERVICE AND SEVENTH BOX FOR INDICATING MICRO OR SMALL OR MEDIUM) AND LAST FIVE BOXES ARE FOR EM NUMBER)

DATE:- 30/01/2015

DEPUTY COMMISSIONER OF INDUSTRIES

PLACE:- GHAZIABAD

DISTRICT INDUSTRIES CENTER

GHAZIABAD

This is a computer generated letter hence no signature is required. You can use this document in your further dealing.

WARNING : ANY WRONG INFORMATION OR VIOLATION OF ANY EXISTING CENTRAL/STATE GOVERNMENT ACT, AUTHORITY IS EXPLICITLY PROHIBITED EITHER NEGLIGENTLY OR OTHERWISE, SUCH ACKNOWLEDGEMENT OBTAINED, WILL BE INVALID AND SHALL HAVE NO LEGAL CLAIMS.



GOVERNMENT OF INDIA
MINISTRY OF CORPORATE AFFAIRS

Registrar of Companies, Delhi
4th Floor , IFCI Tower , 61 , Nehru Place

Certificate of Incorporation

[Pursuant to sub-section (2) of section 7 of the Companies Act, 2013 and rule 8 of the Companies (Incorporation) Rules, 2014]

I hereby certify that PSG ELECTRICALS PRIVATE LIMITED is incorporated on this Twenty Fifth day of November Two Thousand Fourteen under the Companies Act, 2013 and that the company is limited by shares.

The CIN of the company is U40300DL2014PTC273494.

Given under my hand at Delhi this Twenty Fifth day of November Two Thousand Fourteen.

Signature valid
Digitally signed by
Bandook Singh, DN: cn=Bandook Singh, o=Registrar of Companies, ou=Delhi, email=bandook.singh@roc.delhi.nic.in, c=IN
Date: 2014.11.25
13:32:10 GMT+05:30

Afsar Ali
Assistant Registrar of Companies
Delhi

Mailing Address as per record available in Registrar of Companies office:

PSG ELECTRICALS PRIVATE LIMITED
1483, JANTA FLATS, G.T.B. ENCLAVE, DILSHAD GARDEN,
DELHI - 110093,
Delhi, INDIA

